

Smart Ground Multi-Meter

Joe Boyles

Boyles Electronics

SGM

- The Smart Ground[®] Multimeter, or SGM, is a computer controlled multi-function instrument for measuring grounding systems.
- Developed by Dr Sakis Meliopolis with the sponsorship of EPRI.

SGM





SGM

The WinIGS software provides 10 measurement functions:

1. Ground Impedance Measurement
2. Soil Resistivity Measurement
3. Tower Ground Resistance Measurement
4. Touch Voltage Measurement
5. Step Voltage Measurement
6. Ground Mat Impedance Measurement
7. Transfer Voltage Measurement
8. Low Impedance/Continuity Measurement
9. Fall of Potential Method Measurement
10. Oscilloscope Function


1. Ground Impedance Measurement

- The ground impedance measurement function can be applied to any existing grounding system.
- The system under test can be energized or de-energized.
- It measures the ground impedance of the system consisting of all interconnected grounding electrodes as well as nearby grounds connected via shield and neutral wires.

1. Ground Impedance Measurement

- The ground impedance measurement function can be applied to any existing grounding system.
- The system under test can be energized or de-energized.
- It measures the ground impedance of the system consisting of all interconnected grounding electrodes as well as nearby grounds connected via shield and neutral wires.


1. Ground Impedance Measurement



2. Soil Resistivity Measurement

- The soil resistivity function is based on an extension of the four-pin Wenner method.
- The SGM takes simultaneous measurements on nine probes uniformly spaced along a line on the soil surface.
- Provides an equivalent 2-Layer resistivity model.


2. Soil Resistivity Measurement



3. Tower Ground Resistance Measurement

- Measures the ground resistance of an energized or de-energized transmission line tower.
- Shield wires may be connected to the tower ground during measurements.


3. Tower Ground Resistance Measurement



4. Touch Voltage Measurement

- Measures the actual touch voltage at a substation as a function of the fault current.
- The measurement is performed at up to six points near a grounding system.


4. Touch Voltage Measurement



5. Step Voltage Measurement

- Measures the actual step voltage at a substation as a function of the fault current.
- The measurement is performed at a user-selected point near a grounding system.


5. Step Voltage Measurement



6. Ground Mat Impedance Measurement

- This function measures the ground mat impedance without disconnecting the shield or neutral wires which may be bonded to the ground mat.
- Setup and connections are similar to the ground impedance measurements.


6. Ground Mat Impedance Measurement



7. Transfer Voltage Measurement

- Measures the transfer voltage at a user-selected point or ground. This could be a probe at a specific location such as a proposed CFJ site.
- Measures the voltage as a function of the fault current.


7. Transfer Voltage Measurement



8. Low Impedance/Continuity Measurement

- Measures the impedance between any two user selected points of a grounding system.
- The measurement can be performed on energized grounding systems.
- Accurate results can be obtained even in the presence of substantial external electromagnetic noise.
- Requires a current limiting resistor inserted in series with the red electrode.


8. Low Impedance/Continuity Measurement



9. Fall of Potential Method Measurement

- Allows using the SGM to perform a ground impedance measurement using the fall-of-potential method.
- The required setup for this function is the standard fall-of-potential probe arrangement.

9. Fall of Potential Method Measurement




10. Oscilloscope Function

- Allows the SGM to be used as a general purpose six channel waveform data acquisition system.

6. Ground Mat Impedance Measurement

- Probably the single most powerful use of the SGM.
 - Takes advantage of the fact that the impedance of the earth is predominately resistive with virtually no reactive component.
 - The program uses this fact to differentiate between the current that flows through the earth and that which flows through metallic components.
 - The current through the Current Return probe must be minimally 2.0 Amps. Sometimes hard to accomplish.



6. Ground Mat Impedance Measurement

SGM Measurement Parameters

Case Name: CASE_NUMBER_1 Cancel Accept

Function: Ground Mat Impedance Development Options

Time: Monday, January 27, 2014 at 15:35:35

First Run

Data Acquisition

Samples per Channel: 512 1024 2048 4096

Frequency Range: 250 Hz 500 Hz 1000 Hz 2000 Hz

Voltage Probe Calibration

Sequent Simultaneous

Number of Calibrations: 5

Measurements

Number of Measurements: 10

Source Voltage: 150 V 250 V 500 V

Auto Gain Selection Manual Gain Selection

Post-Processing

Correct for Lead Induction

Active Probes: 1' 2E 2' 2B 3' 3B External CT

Power Frequency: 60.00 Hz

Ext. CT Range: 1000 A Range: 1 mV / A 100 A Range: 10 mV / A 10 A Range: 100 mV / A

Special Options

Hood Patterson & DewaForm MEASUREMENT_SETUP - Copyright © A. P. Meliopoulos 1992-2013

SGM

Set Probes Using GPS



Change Format

Cancel

OK

Latitude

Longitude

Distance
from SGM

Decimal Degrees

Decimal Degrees

Feet Meters

SGM

35.24834000

-81.03308000

Err=-46.8

Reference

35.24811000

-81.03289000

101.3

Update Drawing

Update from Drawing

Current Return

35.25023000

-81.03344000

698.6

Probe 1Y

35.24934000

-81.03359000

395.6

Probe 2Y

35.24911000

-81.03362000

324.1

Probe 3Y

35.24883000

-81.03362000

240.8

Probe 1B

35.24935000

-81.03349000

388.6

Probe 2B

35.24908000

-81.03350000

297.9

Probe 3B

35.24883000

-81.03353000

223.7

SGM

Probe Performance Report

Case: **CASE_NUMBER_1**

Probe	Resistance (Ω)	Soil Resistivity (Ω - m)	Capacitance (pF)	Inductance (mH)	Error (%)	
1Y	184.31	91.4	0.00	3.00	2.27	<input type="checkbox"/> Remove
2Y	173.26	85.9	0.00	3.43	2.53	<input type="checkbox"/> Remove
3Y	129.20	64.0	0.00	4.33	6.42	<input type="checkbox"/> Remove
1B	157.67	78.1	0.00	0.20	1.38	<input type="checkbox"/> Remove
2B	476.05	236.0	0.03	0.00	1.35	<input type="checkbox"/> Remove
3B	384.51	190.6	0.01	0.00	3.70	<input type="checkbox"/> Remove
Average* 205.79		Average* 102.0		<small>* NOTE Maximum value is omitted</small>		Cancel Proceed

SGM**Data Acquisition Performance**

Case Name: CASE_NUMBER_1

Injected Current: 8.00 Amperes RMS

Prb #	%Valid	%Error	Resistance (Ohms)	Coherence Average-Squared	Quality	
1Y	80.77	2.45	184.3	0.9971	Very Good	<input type="checkbox"/> Remov
2Y	76.92	2.57	173.3	0.9954	Very Good	<input type="checkbox"/> Remov
3Y	75.64	2.70	129.2	0.9934	Very Good	<input type="checkbox"/> Remov
1B	80.77	2.10	157.7	0.9973	Very Good	<input type="checkbox"/> Remov
2B	78.21	2.22	476.0	0.9961	Very Good	<input type="checkbox"/> Remov
3B	75.64	2.45	384.5	0.9938	Very Good	<input type="checkbox"/> Remov


Cancel**Proceed**

SGM Ground Mat Impedance Report



Case: CASE_NUMBER_1

Ground Mat Impedance versus Frequency



Plot Cursors

Frequency
(Hertz)

60.00

Magnitude
(Ohms)

1.369

Phase
(Degrees)

0.5028

Statistical Analysis

Return

SGM Statistical Analysis



Case: CASE_NUMBER_1

[Return](#)

Error Vs Confidence Level

Conf.%	Error %
0.00	4.0%
0.00	8.0%
7.25	12.0%
99.99	16.0%
100.00	20.0%

Probe Performance Index

1Y	0.12	1B	0.09
2Y	0.11	2B	0.07
3Y	0.05	3B	0.03

8. Low Impedance/Continuity Measurement

- For sites where the continuity or integrity of the ground grid is in question.
- Provides impedance and phase angle of the connection point-to-point.
- Use one spot as the anchor point and move the other test leads to any above-ground point that needs testing.

SGM

Impedance Report

Close

Case Name

Case_1

P_PTP


Time

11/12/2013 08:08

Description

Measure between yards.

Average Impedance



Cursor Values

Frequency

60.00 Hz

Impedance

0.05347 Ohms

Phase

75.39 Degrees

Resistance

0.01349 Ohms

Reactance

0.05174 Ohms

Inductance

0.1372 mH

SGM

Impedance Report

Close

Case Name

Case 1

_PTP


Time

11/12/2013 08:42

Description

From Common point 4 to 9

Average Impedance



Cursor Values

Frequency

60.00 Hz

Impedance

0.02217 Ohms

Phase

87.41 Degrees

Resistance

0.001002 Ohms

Reactance

0.02215 Ohms

Inductance

0.05874 mH

SGM

Impedance Report

[Close](#)**Case Name**

Case 1


_PTP**Time**

11/12/2013 08:45

Description

From Common point 4 to 14

Average Impedance




Cursor Values


Frequency**60.00** Hz**Impedance****0.02236** Ohms**Phase****87.43** Degrees**Resistance****0.001002** Ohms**Reactance****0.02234** Ohms**Inductance****0.05925** mH

4. Touch Voltage Measurement

Case Name	RTA_SUBSTATION_1_2	
Fault Current	1000.0	Amperes
<i>Touch Voltages</i>		
At Probe 1Y	2.75	Volts
At Probe 2Y	3.49	Volts
At Probe 3Y	1.77	Volts
At Probe 1B	3.51	Volts
At Probe 2B	5.25	Volts
At Probe 3B	5.92	Volts



The diagram illustrates a person standing on a ground plane. The person's body is represented by a vertical line with a resistor symbol in the center. The person's right hand is touching a vertical wire that extends upwards. A circuit diagram is shown below the ground plane, consisting of a voltage source labeled V_{TOUCH} connected in series with a resistor. The circuit is connected to the ground plane and the person's feet, representing the touch voltage measurement setup.
















5. Step Voltage Measurement

SGM Step Voltage Report



Case Name

SUBSTATION_1_2

Fault Current

1000.0


Amperes


Step Voltage

0.34

Volts

Return





Locating the Current Return Probe

